

### Slip Resistance Classification of New Pedestrian Surfaces - AS4586:2013

This Test Report Is In Accordance with Appendix A	Wet Pendulum Test
Date Tested:	20 Feb 2024
Test Report Number:	MO200224-6
Client Name & Billing Address:	Next 13 Pty Ltd - 4/67 Araluen Street Kedron Qld 4031
Project Name or Test Location:	4/67 Araluen Street Kedron Qld 4031
Surface Tested :	Oaks - Fine Texture
Wet Pendulum Test carried out using :	Slider 96 (4S) Rubber slider
Any Variations to Standards	N/A
Testing Officer / Approved Signatory:	Mitchell Ording
Pendulum in use - Calibration Date :	#1109 - Munro-Stanley Portable Skid Tester (C: 27.04.23 - BS 7976-3:2002+A1:2013)

Signature of Approved Signatory :

#### Test Results : (Samples and Test Information Supplied by Client)

Sample No.	Swing 1	Swing 2	Swing 3	Swing 4	Swing 5	Mean BPN	SCV :	Surface Picture
Sample 1	45	45	44	43	42	43	N/A	
Sample 2	45	44	44	42	41	42	N/A	
Sample 3	43	43	42	42	40	41	N/A	
Sample 4	45	45	45	44	44	44	N/A	
Sample 5	44	44	43	43	42	43	N/A	

Reported SRV For Test Area : 43

CLASSIFICATION using Slider 96 (4S Slider) P3 = 35 - 44

*Accredited for Compliance with ISO/IEC 17025. The information presented herein and on the Sliptest Report is copyright and is protected by copyright law, any reproduction of this information and test report except in full is prohibited. Sliptest Australia Pty. Ltd. performed this on site test with reference to the following Australian Standard testing criteria, of AS 4586:2013 Classification of new pedestrian surface materials. Appendix A - Wet Pendulum Test Method and Hand Book HB 198: 2014 with reference to AS/NZS 4663: 2004 Slip Resistance measurement of existing pedestrian surfaces and HB 197: 1999. These results do not account for Future Wear, Maintenance or Contamination of this surface once in-situ.*